



NOTES:

1. ALL SERVICES SHALL BE 4" DIAMETER MINIMUM, UNLESS DIRECTED OTHERWISE AND SHALL BE EXTENDED FROM MAIN LINES TO 10' INSIDE OF PROPERTY LINES.
2. MINIMUM SLOPE: 1/4" PER FOOT (2%) OR WHERE APPROVED BY THE DISTRICT 1/8" PER FOOT (1%).
3. CLEAN-OUTS SHALL BE NO MORE THAN 100 FEET APART MEASURED FROM THE UPSTREAM ENTRANCE OF THE CLEANOUT.
4. ALL 90° CONNECTIONS TO MAIN MUST BE CONSTRUCTED WITH ONE 45° BEND AND A WYE.
5. 90° FITTINGS ARE NOT ALLOWED. 90° SHALL BE MADE WITH TWO 45° BENDS OR A COMBO WYE AND 45° BEND.
6. DIRECT NOSE-ON CONNECTIONS ARE USED WHEN CONNECTING TO EXISTING MAIN LINE. ALL NOSE-ON WORK IS TO BE DONE BY DISTRICT PERSONNEL.

NO SCALE



JORDAN BASIN
IMPROVEMENT DISTRICT

**STANDARD SEWER SERVICE
CONNECTION & CLEAN-OUT**

DRAWN:	DESIGNED:	CHECKED:	APPROVED:
DATE AUG 2024	FILE NAME	DRAWING NAME SS-3A	